



A P P R O V A L S ®

Certificate of Suitability

Addendum

Certificate No.: SAA151433

Date of Issue: 24 July 2015

Class Description: Non-Declared
Product Description: Connector

Additional Models

Description

LLT-M14-15002(3,4)F(M)1(2)	Similar to LLT-M12-15002(3)F(M)1(2) except rated 100V~ and with 2, 3 or 4 poles.
LLT-M16-15002(3,4)F(M)1(2)	Similar to LLT-M14-15002(3,4)F(M)1(2) except with thread diameter M16 in lieu of M14.
LLT-M19-25002(3,4)F(M)1(2)	Similar to LLT-M14-15002(3,4)F(M)1(2) except rated 25A and with thread diameter M19 in lieu of M14.
LLT-M19-15005F(M)1(2)	Similar to LLT-M19-25002(3,4)F(M)1(2) except rated 15A and 5 poles in lieu of 2, 3 or 4 poles.
LLT-M22-25002(3,4)F(M)1(2)	Similar to LLT-M19-25002(3,4)F(M)1(2) except rated 25A and thread diameter M22 in lieu of M19.
LLT-M25-30002(3,4)F(M)1(2)	Similar to LLT-M22-25002(3,4)F(M)1(2) except rated 30A and thread diameter M25 in lieu of M22.
LLT-M25-25005(6)F(M)1(2)	Similar to LLT-M19-25002(3,4)F(M)1(2) except for thread diameter M25 in lieu of M19 and 5 or 6 poles in lieu of 2, 3 or 4 poles.
LLT-M29-30002(3,4)F(M)1(2)	Similar to LLT-M25-30002(3,4)F(M)1(2) except for thread diameter M29 in lieu of M25.
LLT-M29-25005(6)F(M)1(2)	Similar to LLT-M25-25005(6)F(M)1(2) except for thread diameter M29 in lieu of M25.

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 24-07-15 151433/2